



ENVIROCON DIRECTIONS FOR USE

FOR DEODORIZATION OF HVAC SYSTEM DUCT WORK:

Fog or spray EnviroCon into system intakes while system is running. Allow enough spray time for EnviroCon to contact air duct system surfaces. Surfaces should be lightly coated. Avoid saturating to a level where product drips or pools. Repeat application as necessary. No dilution necessary - one gallon will treat approximately 1,000 to 1,500 linear feet of duct surface.

FOR MICROBIAL CONTROL OF EVAPORATOR COILS, DRIP PANS AND AIR CONDITIONING PARTS:

Air conditioning system parts should be manually pre-cleaned prior to application using a suitable coil/drip pan cleaner. After cleaning thoroughly, spray EnviroCon onto cleaned surfaces. Do not wipe off. Allow to air dry. No dilution necessary.

FOR MICROBIAL CONTROL OF EVAPORATOR COOLER EXCELSIOR MATS:

Excelsior mats should be thoroughly washed to remove any dirt, debris or slime build-up. Liberally spray EnviroCon onto mats for microbial control and to remove stale, musty odors. Add 2 oz. of EnviroCon per gallon of reservoir water capacity for effective environmental maintenance.

FOR YEAR ROUND MAINTENANCE:

Residential homes and apartment complexes should be treated two times per year or as needed. Commercial and industrial buildings and health care facilities should be treated every month to ensure effective environmental control. EnviroCon should be part of an overall Indoor Air Quality Preventative Maintenance Program.

OTHER ENVIROCON APPLICATIONS:

- Homes
- Offices
- Health Care Facilities
- Hotel & Motel Rooms
- Restaurants
- Cocktail Lounges
- Fire & Flood Areas
- Restrooms
- Sick Rooms
- Gymnasiums
- Locker Rooms
- Basements
- Cars
- Campers
- Motor Homes
- Boats
- Diaper Pails
- Shoes
- Pet Kennels
- Litter Boxes
- Evaporative Coolers
- Waste Disposal
- Refuse Containers
- Kitchens

EPA Reg. No. 9804-3 Est. No. 9804-OK-1

Note: Always keep M.S.D.S. on file in office and in service trucks.

CAUTION: Always use according to label instructions.